



NOTE: GARAGE EXHAUST FANS ON VFD'S CONTROLLED BY CO SENSORS IN THE GARAGE.

FLAG NOTES:

- 1 HVAC CONTRACTOR SHALL PROVIDE SHEET METAL DRAIN PAN BELOW HEAT PUMPS WITH 3/4" DRAIN CONNECTION. DRAIN PIPING PROVIDED BY PLUMBING CONTRACTOR. REFER TO DETAIL 6 ON M400 FOR FAN COIL MOUNTING.

BASEMENT FLOOR PLAN - B1

SCALE: 1/8" = 1'-0"

